

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001


No.F6/DFS/MS/School/NDZ/2022/ 878

Dated:- 10 /08/2022

FIRE SAFETY CERTIFICATE

Certified that the **Bal Bhawan Public School** located at **Pocket B, Mayur Vihar, Phase-II, Delhi-110091** comprised of **Basement + Ground + 03 Upper floors**, owned/occupied by Bal Bhawan Public School has already been issued Fire Safety Certificate vide letter No. **F6/DFS/MS/School/2019/NDZ/1647 dated 20/08/2019**. The premises was re-inspected by the officer concerned of this department on **03/08/2022** in the presence of the Mr. Vividh Gupta (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy class **“Educational Building” (Group B)** with effect from ~~10/8/22~~ renewed for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules 2010, subject to conditions printed below.

Issued on10/8/22..... at New Delhi by.


(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education,
Government of N.C.T. Delhi,
Old Sectt. Delhi – 110054.
2. The Principal,
Bal Bhawan Public School,
Pocket B, Mayur Vihar, Phase-II, Delhi-110091.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry”.
9. Basement shall not be used for children activities.